

Document No. Y-2365-E/F.T * Date of Request 4/10/97 Requested Date of Release (Allow 5 to 10 Days) _____ Page Count 20

Unclassified Title: EXTRACTED PAGES FROM Y-12 DEVELOPMENT TECHNICAL PROGRESS REPORT: PART 2 - INSTRUMENTATION AND EVALUATION

Author's / Requestor's Name S. W. Wiley Telephone No., Pager No. and Plant Address 6-0263, 417-5417, 9106, MS-8023 Account Number 2366-0002

INTENDED AUDIENCE: Public Environmental Regulators NWC DOE Contractors Other ChemRisk

TYPE: Abstract Brochure Co-op Report Formal Report Informal Report
 Invention Disclosure Journal Article News Release Photograph/Visuals Technical Progress Report
 Thesis/Term Paper Videotape Other _____
 Oral Presentation (identify meeting, sponsor, location, date): _____

PATENT OR INVENTION SIGNIFICANCE Yes No (Identify) _____ Document will be published in proceedings Yes No
Document has been previously released Yes No (Reference) _____ Document will be distributed at meeting Yes No

This document contains unclassified controlled information. YES NO [If yes, please identify the category(s) by checking the applicable space(s) below.]

- | | | |
|---|---|---|
| <input type="checkbox"/> Unclassified Controlled Nuclear Information (UCNI) | <input type="checkbox"/> Protected CRADA Information | <input type="checkbox"/> Lockheed Martin Confidential |
| <input type="checkbox"/> Sensitive Nuclear Technology Information | <input type="checkbox"/> Copyrighted Information | <input type="checkbox"/> Lockheed Martin Proprietary |
| <input type="checkbox"/> Export Controlled Information | <input type="checkbox"/> Intellectual Property Information | <input type="checkbox"/> Lockheed Martin Use Only |
| <input type="checkbox"/> Safeguards Information | <input type="checkbox"/> Proprietary Information | <input type="checkbox"/> Energy Systems Sensitive |
| <input type="checkbox"/> Privacy Act Information | <input type="checkbox"/> Applied Technology Information | <input type="checkbox"/> Internal Use Only |
| <input type="checkbox"/> Government Confidential Commercial Information | <input type="checkbox"/> Naval Nuclear Propulsion Information | <input type="checkbox"/> Official Use Only |
| <input type="checkbox"/> Other (Identify) _____ | | |

DIVISION REVIEW AND APPROVAL (Completed by Requesting Division)

<p>CLASSIFICATION REVIEW [Authorized Derivative Classifier (ADC)]</p> <p>Classification of: Title: <u>U</u> Abstract: <u>NA</u></p> <p>DOCUMENT: Level <u>U</u> Category <u>-</u></p> <p><u>R.J. FRASER</u> <u>RJ Fraser</u> <u>APR 9 1997</u></p> <p>Print Name Signature Date</p>	<p>DOCUMENT REQUEST APPROVED (Division/Department Mgr.)</p> <p><u>S. W. Wiley</u> <u>TOA/HS Coordinator</u></p> <p>Please Print Name and Title</p> <p><u>[Signature]</u> <u>4/3/97</u></p> <p>Signature Date</p>
---	--

APPROVAL AND RELEASE (Completed by the Classification/Technical Information Control Office)

<p>CLASSIFICATION OFFICE:</p> <p>Title: <u>Unclassified</u> Abstract: <u>-</u></p> <p>DOCUMENT: Level <u>Unclassified</u> Category <u>-</u></p> <p>Weapons Data <u>-</u> Sigma <u>-</u></p> <p><u>R.F. Smith</u> <u>9 Apr '97</u></p> <p>Y-12 Classification Office Date</p>	<p><input type="checkbox"/> <u>[Signature]</u> <u>4-10-97</u></p> <p>Patent Office Date</p> <p><input type="checkbox"/> _____ Date</p> <p><input type="checkbox"/> _____ Date</p> <p><input type="checkbox"/> _____ Date</p>
--	--

DISTRIBUTION: UNLIMITED [Signature]

LIMITED _____

SPECIAL LIMITED _____

DOE-OSTI: Distribution Category _____

OTHER _____

Distribution of UNC-7721B Form:
Y-12 Central Files
TIO
Requestor [Signature] Date 4-9-97

Distribution Remarks: _____

- Release subject to use of the following admonitory markings and conditions
- Disclaimer Copyright Patent Caution Other
- Copy of Document to Y-12 Central Files (MS-8169, Bldg. 9711-5)

Request Approved

[Signature] 4-10-97

Y-12 Technical Information Office Date

Conditions/Remarks: * Pages 1-4 and 16-30

MASTER

3318

1

Y-12

Y-2365-8/EXT
Y-2365-8 (pages 1-4 and 16-30)

OAK RIDGE Y-12 PLANT

MARTIN MARIETTA

Y-12 DEVELOPMENT DIVISION TECHNICAL PROGRESS REPORT

Part 8 - Instrumentation and
Evaluation Technology (U)

Period Ending August 1, 1987

DISTRIBUTION STATEMENT

[REDACTED]

[REDACTED]

[REDACTED]

[REDACTED]

DESIGN INFORMATION

[REDACTED]

DEPARTMENT OF ENERGY - DECLASSIFICATION REVIEW	
Authority: EO 13526	Classification Change: U
Date: 4-9-87	Classification Change Date: 4-9-87
By: R F Greig	Classification Change Date: 4-9-87
(Name)	Classification Change Date: 4-9-87
Authority: EO 13526	Classification Change: U
Date: 4-9-87	Classification Change Date: 4-9-87

DISTRIBUTION STATEMENT

OPERATED BY
MARTIN MARIETTA ENERGY SYSTEMS, INC.
FOR THE UNITED STATES
DEPARTMENT OF ENERGY

RESTRICTED

[REDACTED]

~~CONFIDENTIAL~~**DISCLAIMER**

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

~~CONFIDENTIAL~~

Date of Issue: February 22, 1988

Y-2365-8 (pages 1-4 and 16)

Y-12 DEVELOPMENT DIVISION
TECHNICAL PROGRESS REPORT

Part 8 - Instrumentation and Evaluation Technology (U)

Compiled by
D. H. Johnson

Period Ending August 1, 1987


Prepared by the
Oak Ridge Y-12 Plant
P.O. Box Y, Oak Ridge, Tennessee 37831
operated by
MARTIN MARIETTA ENERGY SYSTEMS, INC.
for the
U.S. DEPARTMENT OF ENERGY
under contract DE-AC05-84OR21400

CONFIDENTIAL
Distribution
Distribution Agreement in WDA

CONFIDENTIAL
Act

Authorized disclosure

CONFIDENTIAL
Department



* AFFIRMATIVE ACTION
 * PART-TIME
 * DUAL CAPACITY
 * LOAN TO ANOTHER DIVISION
 * ACTING
 * LOAN FROM ANOTHER DIVISION

STACK MONITORING OF URANIUM PARTICULATES AT THE OAK RIDGE Y-12 PLANT

S. A. Wallace and R. J. Reagan

Summary

A prototype system for evaluating the response of a sodium iodide-based detector for observing enriched uranium contaminated filter papers was built. Spectra were taken for characterizing the response to standards, contaminated filters, and thoron daughters. An algorithm was written and tested for triggering an alarm if an excessively fast rate of buildup of uranium contamination occurs.

Introduction

The Y-12 Plant manufactures for the Department of Energy (DOE) precision-machined enriched uranium parts. The room air in areas processing the uranium is vented with fans through ductwork that exits through roof stacks out of the various process buildings. Airborne uranium particulates are trapped in filters in the ductwork. These filters are changed out periodically and burned to recover the trapped material. In the past, the stacks have not been monitored adequately to verify the proper operation of the filters. As a result, the Y-12 Engineering Division has undertaken an extensive program for placing into operation a monitoring system to assure that any aberrant uranium losses from the exhaust stacks would be detected shortly after their occurrence. A one-year fast-track engineering project was approved and funded for designing and erecting the supporting steel platforms for attaching air samplers, purchasing monitors, installing and placing into operation alarm circuits, and turning the system over to the operational divisions.

Prior Work

A report of an evaluation of silicon alpha detection for on-line measurement of the stack losses is presented in ref. 1.

Presentation of Experimental Work

Detection System. A turnkey contract was awarded to Nuclear Measurements Corporation of Indianapolis, Indiana, for furnishing 26 on-line monitors. Loss of enriched uranium up the stacks is measured by pulling a 1-scfm sample stream through a 47-mm Whatman 41 cellulose filter paper. Facing this paper is a beryllium-windowed sodium iodide scintillation detector enclosed within a 3-in.-thick lead pig. For enriched uranium the uranium-234 isotope is present at a 1% assay. With a 248,000-year half-life, this is the most active emitter, having an activity about two orders of magnitude larger than the uranium-235 component. Twenty-eight percent of the uranium-234 decays are accompanied by the emission of L-shell X rays. A 1.5-mm-thick sodium iodide detector captures a fraction of these X rays, and the quantity

THIS PAGE INTENTIONALLY LEFT BLANK.

accumulated over time is the determinant of excessive uranium loss. Figure 6 illustrates the layout of the monitoring system. Figure 7 illustrates the response of the detector for americium-241. The higher peak is located at 59.5 keV, and the lower peak is due to L-shell X rays from neptunium in a 12- to 22-keV band. Figure 8 is the detector response due to a 3077 disintegration-per-minute enriched uranium standard. The standard is a plated film on stainless steel obtained from the Oak Ridge Gaseous Diffusion Plant. Although ambient radon fluctuations were thought to present the monitor with an interference spectrum, this has not been a significant problem. A means of correcting for radon is part of the monitor's capability. This can be accomplished by using spectrum windows. Three energy windows can be used. The system gain is set by selecting the high voltage across the photomultiplier such that the 60-keV peak from an americium check source lies at the same channel number as that obtained from pulses from a precision pulser set to a 1-V amplitude with a 2- μ s rise time and a 5- μ s fall time. Variation in cable length from the photomultiplier output to the pulse-height discrimination input results in each monitor having a different high-voltage setting. The uranium window is selected as those pulses occurring between 0.133 and 0.667 V. This corresponds to an 8- to 40-keV energy window. A second window accepting pulses between 0.833 and 1.667 V is used for radon correction; this corresponds to an energy window of from 50 to 100 keV. A correction algorithm presumes that the spectrum of the enriched uranium and the interferent is known. Figure 9 illustrates two known spectra. Two regions, having window areas 1 and 2, are labeled. The lower solid profile, labeled t, is taken to be that seen after t seconds of measurement. Similarly, the upper solid profile, labeled 3t, is that which would be seen at 3t seconds. If a flat background is present, a shift up in the profile, such as is noted by the profile 3t plus background, would be seen. Background should be constant per unit of time and its profile characterized so that its presence can be removed. The important point is that the ratio of the counts in region 1 to that in region 2 stays constant and independent of the sample interval. Now, given that:

W_1 = counts in region 1 which is the sum of two spectra,

W_2 = counts in region 2 which is the sum of two spectra,

m = ratio of counts due to uranium in region 1 divided by the counts in region 2,

n = ratio of interferent (I) counts in region 1 divided by interferent counts in region 2, then

$$W_1 = mU_2 + nI_2 + B_{kgd1}$$

$$W_2 = U_2 + I_2 + B_{kgd2}$$

or

$$mU_2 + U_2 = \frac{(m + 1) [(W_1 - nW_2) - (B_1 - nB_2)]}{(m - n)},$$




Fig. 6. Schematic of the air-sampling system.

Y-GA 87-5852




Fig. 7. Spectrum of americium-241 observed with thin sodium iodide detector.

~~CONFIDENTIAL~~




Fig. 8. Spectrum of enriched uranium standard showing L-shell X-ray activity from uranium-234.

Y-GA 87-5854




Fig. 9. Spectra at t_D and $3t_D$, L-shell X-ray type.

which is the total uranium counts. Note that if no uranium is present, then W_1 is $Bkgd_1$ and W_2 is $Bkgd_2$, resulting in the total uranium counts being equal to zero.

An experimental verification of this design was implemented by using two single-channel analyzers (SCAs) and two counters, as is seen in the schematic of Fig. 10. An HP-41CX calculator using an IEEE-488 interface to the counters allowed programmed data acquisition to be made. The program (designated NCTR) is given as Appendix A to this report. By using the built-in statistical functions of the calculator, a rate-of-rise algorithm is included for signaling an alarm condition. It is derived by calculating a straight line through the last 15 measurements. Since the filter paper is observed for 1-min periods, the algorithm alarm level is based upon that rate of rise which can be allowed in the same period. The algorithm is a running window in that

Y-GA 87-5855




Fig. 10. Schematic of data-acquisition system.

upon receiving a new measurement, the measurement made 15 min back in time is dropped out. The number of samples to calculate the slope is a keyed entry and can be extended to the last 30 measurements. Likewise, the positive slope, which if exceeded results in alarm, is a keyed entry. Appendix A is a sample of the hardcopy output generated using this data-acquisition system. The turnkey system installed on-line came with an adaptively weighted, exponential-averaging algorithm that was not amenable to conversion to the HP-41CX calculator. Monte Carlo simulations using rising ramps of Poisson-distributed numbers with both algorithms gave similar alarm times as determined by a Statistical Services study.

Although radon and its daughters have not been an interferent problem, two stacks venting Savannah River material have alarmed because of thoron daughters. Figure 11 shows the spectrum obtained as a result of thoron. All the activity is gone after 5 days as can be seen in Fig. 12 taken from the same 47-mm filter obtained from stack 13.

Y-GA 87-5856




Fig. 11. Spectrum showing fresh-filter thoron daughter activity from stack 13.

Y-GA 87-5857




Fig. 12. Spectrum of activity 5-days after that recorded in Fig. 11.

~~CONFIDENTIAL~~

15

~~CONFIDENTIAL~~

Conclusions

A two-channel data-acquisition system was generated for acquiring measurements of the buildup of uranium on a 47-mm filter paper with the presence of an interferent. A rate-of-rise algorithm was implemented for signaling an alarm in the event of too rapid a rate of rise. The system is generic in the sense that either L-shell X rays or alpha-particle energy can be used as the input into a detector located above the filter, or into a combination of the two detectors. Although this system was developed for monitoring a sample stream taken from vent stacks, it can be used in the floor working area for monitoring transient activity in airborne particulate levels. Since it is projected that the levels of this activity are going to be regulated more strictly in the future, the development of this system is also applicable for future monitoring in this application.

Future Work

The installation and operation of the monitors for airborne discharges from stacks is completed as an Engineering endeavor. Future Development work is to be directed to solving any unique problems that may come up as experience identifies problems. At present no problems have surfaced requiring further development effort. The technology has application to working level airborne measurement and may be pursued for that purpose.

Reference

1. Y-12 Development Division Technical Progress Report, Part 10 - Material Characterization Processes and Instrumentation and Computer Applications (U), Y-2362-10, p. 55, Martin Marietta Energy Systems, Inc., Oak Ridge Y-12 Plant, August 11, 1987. SECRET-RD.

APPENDIX A

HP-41 PROGRAM "NCTR"

Appendix A

HP-41 Program "NCTR": Executes two-channel data logging.

01 LBL "NCTR"	21 RCL 03	41 SETDATE	[14]
02 .01	22 SELECT	42 LBL 02	
03 STO 00 [1]	23 REMOTE	43 SF 00	[15]
04 4	24 OUTA	44 CF 01	[16]
05 STO 01	25 CLK24 [7]	45 CF 02	
06 5	26 MDY [8]	46 SIGMAREG 31	[17]
07 STO 02	27 CLX [9]	47 11.040	
08 6	28 FIX 4 [10]	48 CLRGX	[18]
09 STO 03	29 "TIME?HH.MMSS"	49 "NO. PTS?"	
10 AUTOIO [2]	30 PROMPT [11]	50 PROMPT	
11 RCL 01	31 X=0?	51 STO 04	
12 "HCCC"	32 GTO 01 [12]	52 "U RATIO A/B?"	
13 SELECT [3]	33 SETIME [13]	53 PROMPT	
14 REMOTE [4]	34 LBL 01	54 STO 05	
15 OUTA [5]	35 CLX	55 "R RATIO A/B?"	
16 "CCSC"	36 FIX 6	56 PROMPT	
17 RCL 02 [6]	37 "DATE?MM.DDYYYY"	57 STO 06	
18 SELECT	38 PROMPT	58 "BKGRD A?"	
19 REMOTE	39 X=0?	59 PROMPT	
20 OUTA	40 GTO 02	60 STO 07	
61 "BKGRD B?"	81 PRBUF	101 PRBUF	[23]
62 PROMPT	82 "A="	102 RUNSW	
63 STO 08	83 ACA	103 GTO 06	
64 "ALARM SLOPE?"	84 RCL 07	104 LBL 10	
65 PROMPT	85 ACX	105 FC? 49	[24]
66 STO 09	86 PRBUF	106 GTO 05	
67 ADV [19]	87 "B="	107 "LOW BATT"	
68 FIX 1	88 ACA	108 OFF	
69 "STACK MONITOR"	89 RCL 08	109 LBL 05	
70 ACA [20]	90 ACX	110 RCL 00	
71 PRBUF [21]	91 PRBUF	111 RCLSW	[25]
72 "M="	92 "ALARM="	112 X<=Y?	[26]
73 ACA	93 ACA	113 GTO 05	
74 RCL 05	94 RCL 09	114 OUTA	
75 ACX [22]	95 ACX	115 IND	[27]
76 PRBUF	96 PRBUF	116 STO 16	
77 "N="	97 "NO. PTS="	117 RCL 03	
78 ACA	98 ACA	118 SELECT	
79 RCL 06	99 RCL 04	119 OUTA	
80 ACX	100 ACX	120 IND	
121 STO 17	141 FS? 02 [32]	161 /	

~~CONFIDENTIAL~~

CONFIDENTIAL

18

APPENDIX A (continued)

122 LBL 06		142 GTO 21		162 RCL 05	
123 "SC"		143 RCL 14		163 1	
124 RCL 01		144 1		164 +	
125 SELECT		145 -		165 *	
126 OUTA		146 RCL 04		166 STO 20	
127 CLX		147 MOD	[33]	167 STO 18	
128 SETSW	[28]	148 STO 13		168 39	
129 TIME	[29]	149 RCL 16		169 STO 25	
130 STO 23		150 RCL 07		170 XEQ 20	[34]
131 DATE	[30]	151 -		171 RCL 22	
132 STO 11		152 RCL 17		172 STO 19	
133 RCL 14		153 RCL 08		173 RCL 09	
134 X=0?	[31]	154 -		174 X<=Y?	
135 GTO 21		155 RCL 06		175 SF 01	
136 RCL 16		156 *		176 LBL 21	
137 RCL 17		157 -		177 DSE 12	[35]
138 *		158 RCL 05		178 GTO 08	
139 X=0?		159 RCL 06		179 FC? 00	
140 SF 02		160 -		180 GTO 24	
181 CF 00		201 ADV		221 ATIME	[38]
182 40		202 "TIME	"	222 ACA	
183 STO 12		203 ACA		223 " "	
184 ADV		204 " POINT	"	224 ACA	
185 GTO 25		205 ACA		225 FIX 0	
186 LBL 24		206 " COUNT A	"	226 RCL 14	
187 50		207 ACA		227 XEQ 11	
188 STO 12		208 " COUNT B	"	228 RCL 16	
189 12		209 ACA		229 XEQ 11	
190 ACCHR	[36]	210 " COUNT U	"	230 RCL 17	
191 ADV		211 ACA		231 XEQ 11	
192 LBL 25		212 " SLOPE U	"	232 RCL 18	
193 "DATE	"	213 ACA		233 XEQ 11	
194 ACA		214 " STD DEV	"	234 FIX 1	
195 CLA		215 ACA		235 RCL 19	
196 RCL 11		216 PRBUF		236 XEQ 11	
197 FIX 4		217 LBL 08		237 FIX 3	
198 ADATE	[37]	218 RCL 23		238 RCL 38	
199 ACA		219 FIX 4		239 XEQ 11	
200 PRBUF		220 CLA		240 FC? 02	
241 GTO 25		261 LBL 11		281 1	
242 CF 02		262 STO 23		282 +	
243 " MALFUNCTION"		263 CLA		283 RCL 25	
244 ACA		264 ARCL X	[40]	284 +	
245 GTO 19		265 ALENG	[41]	285 STO 26	
246 LBL 25		266 CHS	[42]	286 RCL IND 26	
247 FC? 01		267 10		287 STO 21	

APPENDIX A (continued)

248 GTO 26	268 +	288 RCL 20
249 CF 01	269 " "	289 STO IND 26
250 " ***ALARM***"	270 ASTO 24 [43]	290 RCL 14
251 ACA	271 CLA	291 SIGMA+ [45]
252LBL 26	272LBL 14	292 RCL 04
253 1	273 ARCL 24	293 RCL 14
254 ST+ 14 [39]	274 DSE X	294 X<=Y?
255LBL 19	275 GTO 14	295 GTO 23
256 PRBUF	276 ARCL 23	296 RCL 21
257 RCL 02	277 ACA	297 RCL 14
258 SELECT	278 RTN [44]	298 RCL 04
259 "RCCC"	279LBL 20	299 -
260 GTO 10	280 RCL 13	300 SIGMA- [46]
301LBL 23	311 *	321 X^2
302 RCL 14	312 -	322 ST+ 37
303 RCL 04	313 RCL 36	323 RCL 37
304 X>Y? [47]	314 RCL 32	324 RCL 14
305 RTN	315 *	325 RCL 04
306 RCL 36	316 RCL 31	326 -
307 RCL 35	317 X^2	327 1
308 *	318 -	328 +
309 RCL 31	319 /	329 /
310 RCL 33	320 STO 22	330 SQRT
331 SQRT		
332 RTN		
333 END		

1. STO nn - Copies contents of X-register into R(nn)
2. AUTOIO - Set interface to Auto mode
3. SELECT - Select device as primary device
4. REMOTE - Set primary device to remote mode
5. OUTA - Output ALPHA string to primary device
6. RCL nn - Copy data from a data register into the X-register
7. CLK24 - Sets a 24-hour clock display
8. MDY - Selects month-day-year date format
9. CLX - Clears X-register
10. FIX n - Selects fixed-pt display format with n decimal plcs
11. PROMPT - Displays contents of the Alpha reg and stops exec
12. GTO nn - Transfers execution to specified numeric location
13. SETIME - Sets clock to time specified in X-register
14. SETDATE - Sets clock to date specified in X-register
15. SF nn - Sets flag nn, 00<= nn <=29
16. CF nn - Clears flag nn, 00<= nn <=29
17. SIGMAREG nn - Two-digit address of six consecutive registers
18. CLRGX - Clears every ii the register from R(bbb) thru R(eee)

~~CONFIDENTIAL~~

19

APPENDIX A (continued)

19. ADV - Advances paper if printer is present
20. ACA - Accumulate ALPHA register into print buffer
21. PRBUF - Print the print buffer left-justified
22. ACX - Accumulate X-register into print buffer
23. RUNSW - Runs stopwatch
24. FC? nn - Tests flg nn and skips nxt prgm ln unless flg is clr
25. RCLSW - Returns stopwatch time
26. X<=Y? - Skps nxt instrtn unls numbr in X-reg <= cntnts Y-reg
27. IND - Retrieves ASCII codes of up to 24 chactrs frm pri dev
IND nn _ Argument of STO, RCL, etc specifying registr address
28. SETSW - Sets stopwatch to strng time specified in X-register
29. TIME - Returns number for current time
30. DATE - Returns number for current date
31. X=0? - Skips nxt instrtn unless number in X-register = 0
32. FS? nn - Tests flg nn and skps nxt prgm ln unless flag is set
33. MOD - Remainder whn int y in Y-reg is dved by int x in X-reg
34. XEQ label - Calls spcfd numeric or ALPHA label as subroutine
35. DSE nn - For iiiii.ffffc in R(nn), decrements iiiii by cc and
skips next program step if iiiii + cc > fff.
36. ACCHR - Accumulate character into print buffer
37. ADATE - Appends number in X-reg to ALPHA reg in date format
38. ATIME - Appends number in X-reg to ALPHA reg in time format
39. ST+ nn - Adds number in X-reg to number in R(nn) and places
result in R(nn)
40. ARCL nn - Appends contents of R(nn) to ALPHA register
41. ALENG - Returns number of characters in ALPHA register
42. CHS - Change sign of the operand in X-register
43. ASTO nn - Copies six leftmost chrctrs in ALPHA reg into R(nn)
44. RTN - Returns execution to line following XEQ instruction
that called this subroutine
45. SIGMA+ - Automatic calculation of sums and products for stats
46. SIGMA- - Deletes from statistical function the entry
47. X>Y? - Skps nxt instr unless number in X-reg > numbr in Y-reg

Lines

- 001-103 Set identifiers of IEEE-488 instruments, clear
instruments, set time and date, set flags, input constants,
print input
- 104-108 Battery check
- 109-113 Primary clock loop used every reading
- 114-121 Read counters
- 122-175 Start counters, read current time and date, calculate
COUNT U, check for zero readings and flag, calculate
modulus of sample number MOD number of points in slope
calculation
- 176-191 Calculation for printer pagination
- 192-216 Header print control
- 217-251 Output print control and flag checks for malfunction or
alarm

APPENDIX A (continued)

252-254 Sample index incrementer
255-260 Loop logic
261-278 Print format of output
279-320 Slope calculation
321-332 Standard deviation calculation

CONFIDENTIAL